



**NOTES:**

1. This manhole not to be used for sewers over 27" in diameter.
2. All construction and materials shall conform to ASTM Specification C-478-64 T, unless otherwise shown hereon. All concrete shall be Class C.
3. Clay-Brick shall meet ASTM C216, Grade SW Specification.
4. Manhole steps shall conform to Std. Dwg. R-11A.
5. Any additional opening required to be cut in the field shall be done only as directed by the Engineer.
6. If opening is precast, use rubber boot or similar means in lieu of grout.
7. Bottom section of manhole shall be securely supported in place with brick or concrete block prior to pouring base.
8. 6" precast base may be poured with bottom section of manhole.
9. Precast concrete sections shall be inspected at the location of manufacture and shall be stamped or have such identification noting that said products have been inspected by the City of Columbus and meet their specifications.

<p>STANDARD DIMENSIONS FOR PRECAST CONCRETE PIPE MANHOLE</p>	<p><b>CITY OF REYNOLDSBURG, OHIO</b></p>	
	<p>STANDARD CONSTRUCTION DRAWING</p>	
	<p>Rev. 08-01-01</p>	<p>Date 03-04-86</p>