



NOTES:

1. Pole, Aluminum round tapered. Invisible welded longitudinal seam. Alloy 6063-T6 satin ground finish.
2. Arm - 2" aluminum pile alloy 6063-T6 satin ground finish.
3. Complete with 4"x 6" reinforced handhole cover, bolt on shaft cap, anchor bolts, anchor bolt covers, hardware and anchor bolt circle template.
4. Provide the pole from the following manufacturers only:
 1. HAPCO #21-297 or approved equal interchangeable with same weight per foot, taper per foot, hole patterns, and metal thickness.
5. Mount photocontrol atop pole cap of first pole from service disconnect. Face cell due north. Photocontrol shall be GE CR174H651 with pole top adapter No. G403G010 or approved equal interchangeable. Run 3 #12 USE to Lighting Contractor at Service Disconnect. Photocell wire shall be color coded; black-hot, white-neutral and red-controlled leg.
6. Photocell pole shall have pull box installed adjacent to the foundation.
7. Where "approved interchangeable equal" is called for in these specifications it shall be construed to mean that parts will interchange with the parts called for without the need for modifications or adapting devices. Approval shall be by The City Engineer and the Street Department for Reynoldsburg, Ohio.

STANDARD DIMENSIONS FOR STANDARD POLE DETAIL DRAWING	CITY OF REYNOLDSBURG, OHIO		
	STANDARD CONSTRUCTION DRAWING		
	Rev. 12-28-00	Date 06-91	Dwg. No. R-46